

Document Control Desk, Director  
 Office of Nuclear Material Safety and Safeguards  
 U. S. Nuclear Regulatory Commission  
 Washington, DC 20555-0001

Direct tel: 803-647-1000

cc: USNRC, Region II  
 245 Peachtree Center Ave, NE, Suite 1200  
 Atlanta, Georgia 30303-1257

Our ref: LTR-RAC-20-21-R1

Subject: SNM-1107/70-1151  
 NRC Semi-Annual Discharge Report  
 July - December 2019

February 25, 2020  
 September 8, 2020 R1

*This letter was revised to attach Revision 1 of dose report LTR-EHS-20-17 (LTR-EHS-20-17-R1). Per CAP 2020-5991, it was noted that data in the "Gross Alpha Concentration" column of Attachment 1 had not been updated. Note that all dose calculations are correct and unchanged.*

Dear Sir:

The following report fulfills regulatory requirements as listed in 10 CFR 40.65 and 10 CFR 70.59, "Effluent Monitoring Reporting Requirements." For the six-month period of July 1, 2019 through December 31, 2019, the following quantities of radionuclides were released to the unrestricted area by the Westinghouse Electric Company's Columbia, South Carolina Nuclear Fuel Plant:

| Discharge       | Total 6-month emissions (μCi) | Parameter                         | Total 6-month Measured Concentration | Regulatory Concentration Limit |
|-----------------|-------------------------------|-----------------------------------|--------------------------------------|--------------------------------|
| Gaseous         | 243.52                        | Uranium (analyzed as gross alpha) | 9.4 E <sup>-15</sup> μCi/mL*         | 5 E <sup>-14</sup> μCi/mL      |
| Liquid Effluent | 1,256.4                       | U-234                             | 2.0 E <sup>-08</sup> μCi/mL          | 3 E <sup>-07</sup> μCi/mL      |
|                 | 67.3                          | U-235                             |                                      |                                |
|                 | 224.9                         | U-238                             |                                      |                                |
|                 | 123.2                         | Tc-99                             |                                      |                                |

\*Includes a dispersion factor of 1000 to account for dilution between the release point and the nearest site boundary

As shown above, the effluent releases are within the NRC's regulatory limits designed to protect public health and safety.

Gaseous effluent results were obtained from point source gross alpha analysis of stack gas effluent, and the individual radionuclide activity composition is inferred from the calculated average enrichment (85.04% U-234, 3.38% U-235, and 11.43% U-238). Tc-99 is not reported for gaseous effluents as the quantities of Tc-99 detected during benchmark testing of gaseous emissions were below the thresholds that would necessitate reporting.


Liquid effluent values were obtained by analysis of composite proportional samples prior to discharge to the Congaree River and basing the activity on the calculated average enrichment.

All liquid discharges are pumped through a single discharge line to the Congaree River. Liquid effluent composites were analyzed by alpha spectroscopy, and significant quantities of U-236 were not detected using this method. The total liquid effluent volume released to the Congaree River during the second half of 2019 was 7.71E+07 liters.

Calculated values have been reported for all results, due to variability of minimum detection concentrations (MDC). Negative values are reported as zero.

To meet the requested dosage information outlined in Regulatory Guide 4.16, Section 6.1, LTR-EHS-20-17-R1, "Annual Assessment of Public Dose due to Liquid and Gaseous Effluents" is attached.

Sincerely,



Jeff Ferguson  
Manager, Environment, Health and Safety

Attachment:

LTR-EHS-20-17-R1, "Annual Assessment of Public Dose due to Liquid and Gaseous Effluents"



Westinghouse Electric Company  
Nuclear Fuel  
Columbia Fuel Site  
5801 Bluff Rd  
Hopkins, South Carolina 29061  
USA

To: Cynthia Logsdon, Diana Joyner

Date: May 14, 2020

cc: Jeff Ferguson, Nancy Parr, Anna Pearson, Amanda Spalding

From: David Wagoner  
Ext: 1919  
Fax: 803.695.4158

Your ref:  
Our ref: LTR-EHS-20-17 Rev. 1

Subject: **Annual Assessment of Public Dose due to Liquid and Gaseous Effluents**

Effluents released from plant operations are monitored to determine the quantities of radionuclides discharged into the environment. The cumulative radioactivity released is summarized semi-annually and annually and input into models developed by the NRC and EPA to estimate the dose to the public.

The whole body and organ dose via the following pathways were determined in this assessment:

**Dose due to Gaseous Effluents by Direct Inhalation**

- The whole body dose was estimated using the EPA's COMPLY Code at level 2 complexity. The organ dose was estimated using the calculated X/Q factor for stack number 1247 (Hot Oil Room Ex.), the measured release quantity, and the dose conversion factors from Federal Guidance Report No 11, "Limiting Values of Radionuclide Intake and Air concentration Factors for Inhalation, Submersion, and Ingestion" (FGR 11).

**Dose due to Liquid Effluents by Ingestion of Potable Water**

- Estimated using equations and recommended values in Regulatory Guide 1.109, Doses from Liquid Effluent Pathways (RG1.109). Dose conversion factors were taken from FGR 11.

**Dose due to Liquid Effluents by Ingestion of Fish**

- Estimated using equations and recommended values in RG 1.109. Dose conversion factors were taken from FGR 11.

**Dose due to Liquid Effluents by Irradiation from Shoreline Deposition**

- Estimated using equations and recommended values in RG 1.109. Dose conversion factors were taken from Federal Guidance report No 12, "External Exposure to Radionuclides in Air, Water, and Soil"

Bounding dose assessments for direct inhalation and for ingestion are performed using conservative assumptions to determine the maximum potential dose to a hypothetical individual member of the public. The inhalation dose is determined for the hypothetical individual standing at the nearest site boundary (595 meters) for twelve months. The ingestion dose from liquid

effluent and external dose from sediment deposition is determined at the point at which the liquid effluent leaves the diffuser in the Congaree River.

The release rates for gaseous effluent are determined by gross alpha measurements performed on daily air samples, one per stack for 47 stacks (Attachment 1). The release rates for liquid effluent are determined by isotopic analysis of composite liquid effluent samples taken monthly (Attachment 3). Based on these results, the following quantities were released in calendar year 2019:

- 446.35  $\mu$ Ci of Uranium in gaseous effluent
- 3.83 mCi of Uranium in liquid effluent
- 1.10 mCi of Technetium in liquid effluent

Using these results and the methods previously mentioned the whole body dose, dose to the bone, and dose to the lung were determined for an individual present at the nearest site boundary. Table 1 provides a summary of the results for each pathway. The gaseous and liquid effluents released during 2019 resulted in a potential whole body dose of 0.16 mrem and lung dose of 1.6 mrem to an individual present at the nearest site boundary. The dose to the bone is negligible. The estimated whole body dose is well below the 25 mrem annual dose limit and the 1 mrem annual ALARA goal for a member of the public.


**Table 1.** 2019 Annual Dose to the Public from Liquid and Gaseous Effluents

|                          | <b>Whole Body Dose<br/>(mrem/yr)</b> | <b>Organ Dose - Bone<br/>(mrem/yr)</b> | <b>Organ Dose - Lung<br/>(mrem/yr)</b> |
|--------------------------|--------------------------------------|--|--|
| <b>Gaseous Effluents</b> |                                      |  |  |
| Direct inhalation*       | 0.16                                 | 6.1E-03                                | 1.6                                    |
| <b>Liquid Effluents</b>  |                                      |  |  |
| Potable Water            | 9.1E-05                              | 1.4E-03                                | -                                      |
| Aquatic Food (Fish)      | 5.3E-06                              | 7.7E-05                                | -                                      |
| Shoreline Deposition     | 3.9E-09                              | -                                      | -                                      |
| <i>Total (mrem)</i>      | <i>0.16</i>                          | <i>7.6E-03</i>                         | <i>1.6</i>                             |

\* Assumes 80 % residence time

There were no changes in source material and no release points were added or removed during 2019. Based on updated emissions testing in support of the SCDHEC air permit renewal, the orientation and stack height for the S-958 scrubber (samples 1233 and 1234) was modified to optimize atmospheric dispersion for nitrogen oxides (NO<sub>x</sub>) in 2019. The attachments below illustrate the method used to calculate each result listed in Table 1.

- Attachment 1: 2019 Gaseous Effluent Discharges
- Attachment 2: Lung/Bone Organ Dose due to Gaseous Effluent
- Attachment 3: 2019 Liquid Effluent Discharges
- Attachment 4: Whole Body Dose from Liquid Effluent Pathways - Potable Water
- Attachment 5: Dose to the Bone Surface from Liquid Effluent Pathways - Potable Water
- Attachment 6: Whole Body Dose from Liquid Effluent Pathways - Aquatic Foods
- Attachment 7: Dose to the Bone Surface from Liquid Effluent Pathways - Aquatic Foods
- Attachment 8: Whole Body Dose from Liquid Effluent Pathways – Shoreline Deposits
- Attachment 9: 2019 Isotopic Fractions
- Attachment 10: Comply Results



David Wagoner, CHP  
Radiation Safety Engineer  
EH&S Operations



Anna Pearson  
Manager, RSO  
EH&S Operations

# Attachment 1 2019 Gaseous Effluent Discharges

| Sampling Station | Location Description | Stack Height (m) | Gross Alpha Concentration* (uCi/ml) | 1st Half (Jan-Jun)   |               | 2nd Half (July-Dec) |                 | Total uCi Released | Release Rate (Ci/s) |  |  |
|------------------|----------------------|------------------|-------------------------------------|----------------------|---------------|---------------------|-----------------|--------------------|---------------------|--|--|
|                  |                      |                  |                                     | uCi Uranium Released | Released      | U234                | U235            |                    | U238                |  |  |
| 1207             | MET LAB EXHAUST      | 10               | 1.36E-13                            | 0.97                 | 1.40          | 2.37                | 6.39E-14        | 2.56E-15           | 8.59E-15            |  |  |
| 1239             | MAINT WELD EX        | 11               | 2.61E-13                            | 2.36                 | 5.36          | 7.72                | 2.08E-13        | 8.32E-15           | 2.80E-14            |  |  |
| 1243             | AC-8                 | 11               | 8.15E-14                            | 4.77                 | 4.85          | 9.62                | 2.59E-13        | 1.04E-14           | 3.49E-14            |  |  |
| 1222             | CALC COMB GAS LN 1   | 12               | 1.40E-13                            | 0.21                 | 0.50          | 0.71                | 1.91E-14        | 7.65E-16           | 2.57E-15            |  |  |
| 1223             | CALC COMB GAS LN 2   | 12               | 1.64E-13                            | 0.31                 | 0.54          | 0.85                | 2.29E-14        | 9.16E-16           | 3.08E-15            |  |  |
| 1224             | CALC COMB GAS LN 3   | 12               | 1.29E-13                            | 0.24                 | 0.42          | 0.66                | 1.78E-14        | 7.12E-16           | 2.39E-15            |  |  |
| 1225             | CALC COMB GAS LN 4   | 12               | 1.45E-13                            | 0.28                 | 0.46          | 0.74                | 2.00E-14        | 7.98E-16           | 2.68E-15            |  |  |
| 1226             | CALC COMB GAS LN 5   | 12               | 8.42E-14                            | 0.21                 | 0.22          | 0.43                | 1.16E-14        | 4.64E-16           | 1.56E-15            |  |  |
| 1228             | CHEM LAB EX #3       | 12               | 1.51E-13                            | 0.45                 | 1.06          | 1.51                | 4.07E-14        | 1.63E-15           | 5.47E-15            |  |  |
| 1231             | DEV LAB EX #2        | 12               | 3.36E-13                            | 3.52                 | 6.42          | 9.94                | 2.68E-13        | 1.07E-14           | 3.60E-14            |  |  |
| 1237             | ABF HOOD TORIT EX    | 12               | 8.79E-14                            | 1.94                 | 1.96          | 3.90                | 1.05E-13        | 4.20E-15           | 1.41E-14            |  |  |
| 1241             | PELLET LINE 6        | 12               | 8.60E-14                            | 3.77                 | 3.70          | 7.47                | 2.01E-13        | 8.05E-15           | 2.71E-14            |  |  |
| 1247             | HOT OIL RM EX        | 12               | 7.02E-13                            | 43.07                | 42.33         | 85.40               | 2.30E-12        | 9.21E-14           | 3.10E-13            |  |  |
| 1201             | FURNACE EX LINE 1    | 13               | 8.17E-14                            | 3.53                 | 3.56          | 7.09                | 1.91E-13        | 7.64E-15           | 2.57E-14            |  |  |
| 1202             | FURNACE EX LINE 2    | 13               | 8.91E-14                            | 3.79                 | 3.95          | 7.74                | 2.09E-13        | 8.34E-15           | 2.81E-14            |  |  |
| 1203             | FURNACE EX LINE 3    | 13               | 8.95E-14                            | 3.51                 | 4.26          | 7.77                | 2.10E-13        | 8.38E-15           | 2.82E-14            |  |  |
| 1204             | FURNACE EX LINE 4    | 13               | 8.12E-14                            | 3.49                 | 3.55          | 7.04                | 1.90E-13        | 7.59E-15           | 2.55E-14            |  |  |
| 1205             | FURNACE EX LINE 5    | 13               | 8.05E-14                            | 3.46                 | 3.54          | 7.00                | 1.89E-13        | 7.55E-15           | 2.54E-14            |  |  |
| 1206             | NEW DECON ROOM       | 13               | 8.65E-14                            | 2.19                 | 2.24          | 4.43                | 1.19E-13        | 4.78E-15           | 1.61E-14            |  |  |
| 1208             | INCINERATOR EX       | 13               | 2.41E-13                            | 8.19                 | 6.04          | 14.23               | 3.84E-13        | 1.53E-14           | 5.16E-14            |  |  |
| 1209             | SUPPL INCIN EX       | 13               | 1.16E-13                            | 1.24                 | 2.18          | 3.42                | 9.22E-14        | 3.69E-15           | 1.24E-14            |  |  |
| 1217             | CONV ENCL EX 4-C     | 13               | 1.39E-13                            | 6.72                 | 10.24         | 16.96               | 4.57E-13        | 1.83E-14           | 6.15E-14            |  |  |
| 1218             | CONV ENCL EX 4-D     | 13               | 2.37E-13                            | 0.00                 | 0.00          | 0.00                | 0.00E+00        | 0.00E+00           | 0.00E+00            |  |  |
| 1219             | CONV EMERG EX 4E     | 13               | 3.38E-13                            | 0.69                 | 1.27          | 1.96                | 5.28E-14        | 2.11E-15           | 7.10E-15            |  |  |
| 1221             | DECON ROOM EX        | 13               | 4.55E-13                            | 5.55                 | 14.67         | 20.22               | 5.45E-13        | 2.18E-14           | 7.33E-14            |  |  |
| 1230             | DEV LAB EX #1        | 13               | 2.20E-13                            | 2.26                 | 4.24          | 6.50                | 1.75E-13        | 7.01E-15           | 2.36E-14            |  |  |
| 1232             | PELLET COMBINED EX   | 13               | 9.64E-14                            | 6.50                 | 7.74          | 14.24               | 3.84E-13        | 1.54E-14           | 5.16E-14            |  |  |
| 1229             | HP LAB EX            | 15               | 9.22E-14                            | 0.74                 | 0.94          | 1.68                | 4.53E-14        | 1.81E-15           | 6.09E-15            |  |  |
| 1233             | SOLVENT EXT N EX     | 15               | 8.86E-14                            | 3.66                 | 4.26          | 7.92                | 2.14E-13        | 8.54E-15           | 2.87E-14            |  |  |
| 1234             | SOLVENT EXT S EX     | 15               | 2.90E-13                            | 1.60                 | 2.72          | 4.32                | 1.16E-13        | 4.66E-15           | 1.57E-14            |  |  |
| 1236             | MAP COMBINED         | 15               | 2.52E-13                            | 0.00                 | 0.00          | 0.00                | 0.00E+00        | 0.00E+00           | 0.00E+00            |  |  |
| 1240             | AC-3                 | 15               | 9.35E-14                            | 4.72                 | 6.32          | 11.04               | 2.98E-13        | 1.19E-14           | 4.00E-14            |  |  |
| 1246             | AC-4                 | 15               | 8.20E-14                            | 4.93                 | 5.03          | 9.96                | 2.69E-13        | 1.07E-14           | 3.61E-14            |  |  |
| 1251             | WATERGLASS SCR S1190 | 15               | 8.06E-14                            | 2.95                 | 2.99          | 5.94                | 1.60E-13        | 6.40E-15           | 2.15E-14            |  |  |
| 1210             | CONV 1-A EX          | 16               | 1.45E-13                            | 10.45                | 8.38          | 18.83               | 5.08E-13        | 2.03E-14           | 6.82E-14            |  |  |
| 1211             | CONV 1-B EX          | 16               | 2.49E-13                            | 0.00                 | 0.00          | 0.00                | 0.00E+00        | 0.00E+00           | 0.00E+00            |  |  |
| 1212             | S1030 A              | 16               | 1.96E-13                            | 17.29                | 26.98         | 44.27               | 1.19E-12        | 4.77E-14           | 1.60E-13            |  |  |
| 1213             | S1030 B              | 16               | 3.11E-13                            | 1.12                 | 2.38          | 3.50                | 9.44E-14        | 3.77E-15           | 1.27E-14            |  |  |
| 1227             | CHEM LAB EX #2       | 16               | 4.58E-13                            | 2.87                 | 5.51          | 8.38                | 2.26E-13        | 9.03E-15           | 3.04E-14            |  |  |
| 1220             | CHEM LAB FILT EX     | 17               | 9.23E-14                            | 7.27                 | 8.77          | 16.04               | 4.32E-13        | 1.73E-14           | 5.81E-14            |  |  |
| 1242             | AC-5                 | 17               | 8.67E-14                            | 4.88                 | 5.36          | 10.24               | 2.76E-13        | 1.10E-14           | 3.71E-14            |  |  |
| 1244             | AMMON FUME SCR 1008A | 17               | 1.01E-13                            | 3.16                 | 2.81          | 5.97                | 1.61E-13        | 6.44E-15           | 2.16E-14            |  |  |
| 1245             | AMMON FUME SCR 1008B | 17               | 1.89E-13                            | 0.00                 | 0.00          | 0.00                | 0.00E+00        | 0.00E+00           | 0.00E+00            |  |  |
| 1238             | IFBA EXHAUST         | 18               | 8.02E-14                            | 5.85                 | 5.97          | 11.82               | 3.19E-13        | 1.27E-14           | 4.28E-14            |  |  |
| 1248             | ERBIA FURNACE EX     | 18               | 8.06E-14                            | 10.16                | 10.41         | 20.57               | 5.55E-13        | 2.22E-14           | 7.46E-14            |  |  |
| 1249             | ERBIA SCRUBBER EX    | 18               | 8.12E-14                            | 5.51                 | 5.49          | 11.00               | 2.97E-13        | 1.19E-14           | 3.99E-14            |  |  |
| 1250             | ERBIA CHANGE ROOM    | 18               | 8.32E-14                            | 2.45                 | 2.50          | 4.95                | 1.33E-13        | 5.34E-15           | 1.79E-14            |  |  |
| <b>Total</b>     |                      |                  |                                     | <b>202.83</b>        | <b>243.52</b> | <b>446.35</b>       | <b>1.20E-11</b> | <b>4.81E-13</b>    | <b>1.62E-12</b>     |  |  |

\*Concentration LLD is 8E-14 uCi/ml

Attachment 2  
Lung/Bone Organ Dose due to Gaseous Effluents

|  | 1st half (Jan-Jun)<br>uCi Uranium<br>43.07 | 2nd half (Jul-Dec)<br>uCi Uranium<br>42.33 | Total<br>uCi released<br>85.40 | EPA<br>Comply Run Results<br>Dose (mrem/yr)<br>Stack height (m)<br>Release Rate (Ci/s) |                         |                                     |  |
|--|--|--|--------------------------------|--|-------------------------|-------------------------------------|--|
| <b>STACK IDENTIFICATION</b><br>Hot Oil Room<br>use highest release to calculate X/Q used by COMPLY |  |  |                                |  |                         |                                     |  |
| Dose from comply<br>release quantity   | 0.04600<br>85.40<br>8.54E-05               | mrem/yr<br>uCi<br>Ci                       |                                |  |                         | 4.60E-02<br>12<br>U-234<br>2.30E-12 | U-235<br>9.21E-14<br>U-238<br>3.10E-13 |
| App E table E-5<br>Effective Dose conversion   | 8000.00                                    | m3/yr                                      |                                |  |                         |                                     |  |
| EPA FGR 11 p150-151  |  |  |                                |  |                         |                                     |  |
| U-234  | 3.58E-05                                   | Sv/Bq                                      | 85.03%                         |  |                         |                                     |  |
| U-235  | 3.32E-05                                   | Sv/Bq                                      | 3.40%                          |  |                         |                                     |  |
| U-238  | 3.20E-05                                   | Sv/Bq                                      | 11.43%                         |  |                         |                                     |  |
| weighted dose conversion   | 3.52E-05                                   | Sv/Bq                                      |                                |  |                         |                                     |  |
| conversion factor  | 3700.00                                    | mrem/pCi= factor* Sv/Bq                    |                                |  |                         |                                     |  |
| weighted dose conversion   | 0.1303                                     | mrem/pCi                                   |                                |  |                         |                                     |  |
|  |  |  | equations                      |  |                         |                                     |  |
| Dose (mrem) = R(a)*3.17e4*Q*(X/Q)*effective Dose conversion  |  |  | see RG1.109-25                 |  |                         |                                     |  |
| Dose (mrem)/(R(a)*3.17e4*Q*effective Dose conversion)=(X/Q)  |  |  |                                |  |                         |                                     |  |
|  | 1.63E-05                                   | X/Q  |                                |  |                         |                                     |  |
| Estimate Lung Dose using X/Q and annual releases for 2019  |  |  |                                | Estimate Bone Dose using X/Q and annual releases for 2019                              |                         |                                     |  |
| App E table E-5<br>Lung Organ Dose conversion  |  |  |                                |  |                         |                                     |  |
| EPA FGR 11 p150-151  |  |  |                                |  |                         |                                     |  |
| U-234  | 2.98E-04                                   | Sv/Bq                                      | 85.03%                         | 1.13E-06   | Sv/Bq                   |                                     |  |
| U-235  | 2.76E-04                                   | Sv/Bq                                      | 3.40%                          | 1.05E-06   | Sv/Bq                   |                                     |  |
| U-238  | 2.66E-04                                   | Sv/Bq                                      | 11.43%                         | 1.07E-06   | Sv/Bq                   |                                     |  |
| weighted dose conversion   | 2.93E-04                                   | Sv/Bq                                      |                                | 1.11E-06   | Sv/Bq                   |                                     |  |
| conversion factor  | 3700.00                                    | mrem/pCi= factor* Sv/Bq                    |                                | 3700.00  | mrem/pCi= factor* Sv/Bq |                                     |  |
| weighted dose conversion   | 1.0848                                     | mrem/pCi                                   |                                | 4.11E-03   | mrem/pCi                |                                     |  |
| release quantity   | 446.35<br>4.46E-04                         | uCi<br>Ci                                  |                                | 446.35<br>4.46E-04   | uCi<br>Ci               |                                     |  |
| <b>Lung *</b><br>assume 80% residence  | 1.60                                       | mrem                                       | <b>Bone *</b>                  | 6.07E-03   | mrem                    |                                     |  |

# Attachment 3 - 2019 Liquid Effluent Discharges

2019

| Month                   | Liquid Effluent Discharges |                   | Isotopic Uranium Measured Concentrations |            |            |               | Tc-99 Measured Concentrations | Sum U & Tc-99 pCi/L | Total uCi/month Released (based on monthly GEL discharge samples) |                    |               |                                | Measurement Uncertainty / Error |            |            |              | Uncertainty / Error |              |              |               |
|-------------------------|----------------------------|-------------------|--|------------|------------|---------------|-------------------------------|---------------------|---|--------------------|---------------|--------------------------------|---------------------------------|------------|------------|--------------|---------------------|--------------|--------------|---------------|
|                         | Actual kg/month            | Actual gal/month  | U234 pCi/L                               | U235 pCi/L | U238 pCi/L | Total U pCi/L |                               |                     | Tc-99 pCi/L   | U234 pCi/L         | U235 pCi/L    | U238 pCi/L                     | Tc-99 pCi/L                     | U234 pCi/L | U235 pCi/L | U238 pCi/L   | Tc-99 pCi/L         | U234 (uCi)   | U235 (uCi)   | U238 (uCi)    |
| January                 | 3484.056                   | 3,484,056         | 16.9                                     | 1.57       | 3.66       | 22.1          | 5.89                          | 28.0                | 222.9   | 20.7               | 48.3          | 77.7                           | 1.7                             | 0.6        | 0.8        | 22.6         | 7.8                 | 10.5         | 10.5         | 231.5         |
| February                | 2906.489                   | 2,906,489         | 28.2                                     | 1.83       | 5.58       | 35.6          | 20.50                         | 56.1                | 310.2   | 20.1               | 61.4          | 225.5                          | 1.5                             | 0.4        | 0.7        | 21.4         | 4.7                 | 7.2          | 7.2          | 235.4         |
| March                   | 3436.647                   | 3,436,647         | 34.4                                     | 1.86       | 6.88       | 43.1          | 14.60                         | 57.7                | 447.5   | 24.2               | 89.5          | 189.9                          | 1.5                             | 0.4        | 0.7        | 26.9         | 5.0                 | 8.5          | 8.5          | 349.9         |
| April                   | 2717.148                   | 2,717,148         | 26.6                                     | 1.03       | 2.88       | 30.5          | 28.10                         | 58.6                | 273.6   | 10.6               | 29.6          | 289.0                          | 3.5                             | 0.9        | 1.2        | 22.0         | 9.0                 | 12.8         | 12.8         | 226.3         |
| May                     | 2927.418                   | 2,927,418         | 28.4                                     | 1.08       | 4.94       | 34.4          | 5.35                          | 39.8                | 314.7   | 12.0               | 54.7          | 59.3                           | 2.0                             | 0.4        | 0.8        | 22.6         | 21.8                | 4.8          | 9.2          | 250.4         |
| June                    | 3563.415                   | 3,563,415         | 20.8                                     | 1.05       | 3.64       | 25.5          | 10.30                         | 35.8                | 280.5   | 14.2               | 49.1          | 138.9                          | 1.9                             | 0.5        | 0.8        | 21.7         | 25.0                | 6.4          | 10.5         | 292.7         |
| July                    | 3102.469                   | 3,102,469         | 16.0                                     | 0.89       | 3.26       | 20.1          | 1.62                          | 21.7                | 187.9   | 10.4               | 38.3          | 17.8                           | 1.7                             | 0.4        | 0.6        | 25.1         | 23.2                | 6.6          | 9.5          | 308.8         |
| August                  | 4029.124                   | 4,029,124         | 17.1                                     | 1.08       | 2.81       | 21.0          | 0.00                          | 21.0                | 260.8   | 16.5               | 42.9          | 0.0                            | 1.5                             | 0.4        | 0.4        | 23.3         | 11.8                | 2.9          | 5.0          | 276.1         |
| September               | 3130.477                   | 3,130,477         | 15.3                                     | 0.71       | 2.57       | 18.6          | 0.90                          | 19.5                | 181.3   | 8.4                | 30.5          | 10.7                           | 1.0                             | 0.2        | 0.4        | 15.5         | 4.0                 | 6.6          | 6.6          | 207.7         |
| October                 | 3250.124                   | 3,250,124         | 15.1                                     | 0.68       | 2.66       | 18.4          | 0.48                          | 18.9                | 185.8   | 8.4                | 32.7          | 5.9                            | 1.3                             | 0.3        | 0.5        | 24.2         | 17.2                | 4.4          | 7.4          | 200.3         |
| November                | 3195.197                   | 3,195,197         | 12.9                                     | 0.63       | 2.32       | 15.9          | 7.34                          | 23.2                | 158.9   | 7.6                | 28.1          | 88.8                           | 1.4                             | 0.4        | 0.6        | 24.0         | 17.2                | 4.4          | 7.4          | 200.3         |
| December                | 3651.177                   | 3,651,177         | 20.6                                     | 1.16       | 3.80       | 25.6          | 0.00                          | 25.6                | 284.7   | 16.0               | 52.5          | 0.0                            | 0.9                             | 0.3        | 0.4        | 12.4         | 3.5                 | 5.4          | 5.4          | 348.3         |
| <b>Total</b>            | <b>39393.741</b>           | <b>39,393,741</b> |  |            |            |               |                               |                     | <b>3105.7</b>   | <b>169.1</b>       | <b>557.5</b>  | <b>1103.5</b>                  |                                 |            |            | <b>240.7</b> | <b>64.8</b>         | <b>101.8</b> | <b>101.8</b> | <b>3480.1</b> |
| <b>Liters (L)</b>       |                            |                   |  |            |            |               |                               |                     | <b>3832.3</b>   | <b>uCi Uranium</b> | <b>4935.8</b> | <b>uCi Uranium &amp; Tc-99</b> |                                 |            |            |              |                     |              |              |               |
| <b>Milliliters (ml)</b> |                            |                   |  |            |            |               |                               |                     |   |                    |               |                                |                                 |            |            |              |                     |              |              |               |

### LIQUID DISCHARGES

| Radionuclide   | LLD (uCi/ml) | Quantity Released (uCi) | Error    | Average Concentration Released (uCi/ml) |
|----------------|--------------|-------------------------|----------|---|
| U234           | 6.00E-10     | 3105.7                  | +/- 241  | 2.08E-08                                |
| U235           | 6.00E-10     | 169.08                  | +/- 65   | 1.13E-09                                |
| U238           | 6.00E-10     | 557.48                  | +/- 102  | 3.74E-09                                |
| <b>Total U</b> |              | <b>3832.3</b>           |          | <b>2.57E-08</b>                         |
| <b>Tc-99</b>   | 6.00E-10     | 1103.5                  | +/- 3480 | 7.40E-09                                |
| <b>Total</b>   |              | <b>4935.8</b>           |          | <b>5.88E-08</b>                         |



**Attachment 4  
Whole Body Dose from Liquid Effluent Pathways - Potable Water**

| Whole Body-Ingestion             |  |                   | Usage by adult/yr                                 |  | Dilution at diffuser                           |                   | Average discharge |                   | EPA Limiting Values of Radioisotope Intake |                   | Effective         |                   | Bone              |                   | Effective         |                   | Bone              |                   | Environmental Assessment for renewam ...SNM-1107 May 1985 |                   |
|----------------------------------|--|-------------------|---|--|--|-------------------|-------------------|-------------------|--|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|---|-------------------|
| 730 liters                       | 31293 mixing - dilution  | U                 | 10CFR20   | 7.3 x 10 <sup>4</sup> (m <sup>3</sup> ) which is the annual water intake of "Reference Man." | 9388 cubic feet/sec                            | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 3.23567E-10 U-234                | 1.12404E-13 U-235  | 1.77058E-14 U-238 | 3.71407E-10 Tc-99                                 | 0.999999996 U-234  | 1.000000000 U-235                              | 0.999999995 U-238 | 1.000000000 U-235 | 0.999999995 U-238 | 1.000000000 U-235                          | 0.999999995 U-238 | 1.000000000 U-235 | 0.999999995 U-238 | 1.000000000 U-235 | 0.999999995 U-238 | 1.000000000 U-235 | 0.999999995 U-238 | 1.000000000 U-235 | 0.999999995 U-238 | 1.000000000 U-235   | 0.999999995 U-238 |
| 730 liters                       | 31293 mixing - dilution  | U                 | 10CFR20   | 7.3 x 10 <sup>4</sup> (m <sup>3</sup> ) which is the annual water intake of "Reference Man." | 9388 cubic feet/sec<br>3.00E-01 cubic feet/sec | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 31293 mixing - dilution          | Dilution at diffuser   | M                 | Congaree Flow<br>Effluent Flow                    | 7.3 x 10 <sup>4</sup> (m <sup>3</sup> ) which is the annual water intake of "Reference Man." | 9388 cubic feet/sec<br>3.00E-01 cubic feet/sec | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 0.3 cubic ft/sec                 | Average discharge  | F                 |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 2.83E-04 U-234                   | mRem/pCi   | D                 | EPA Limiting Values of Radioisotope Intake        | 1988   | 1988   | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 2.66E-04 U-235                   | mRem/pCi   | D                 | FRG no 11   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 2.55E-04 U-238                   | mRem/pCi   | D                 | Exposure-to-dose conversion factors for ingestion |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.46E-06 Tc-99                   | mRem/pCi   | D                 |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 12 hrs                           | transit time   | t-p               |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 3.23567E-10 U-234                | decay const  | A                 | reg guide 1.109                                   | table E-15   |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.12404E-13 U-235                | decay const  | A                 | Nuclide   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.77058E-14 U-238                | decay const  | A                 | URANIUM234  | T(1/2) yr  | T(1/2) hr                                      | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 3.71407E-10 Tc-99                | decay const  | A                 | URANIUM235  | 2.45E+05   | 2.14E+09                                       | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 0.999999996 U-234                | exp(-lambda t)   |                   | URANIUM238  | 7.04E+08   | 6.17E+12                                       | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.000000000 U-235                | exp(-lambda t)   |                   | TC-99   | 4.47E+09   | 3.91E+13                                       | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 0.999999995 U-238                | exp(-lambda t)   |                   |   | 2.13E+05   | 1.87E+09                                       | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| Activity Released                |  |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 3.106E-03 U-234 release fraction | Ci   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.691E-04 U-235 release fraction | Ci   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 5.575E-04 U-238 release fraction | Ci   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.104E-03 Tc-99 release fraction | Ci   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| check U sum                      | 0.00383  |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 8.80E-07 U-234                   | release fraction *dose factor*exp(-lambda t)   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 4.50E-08 U-235                   | release fraction *dose factor*exp(-lambda t)   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.42E-07 U-238                   | release fraction *dose factor*exp(-lambda t)   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.61E-09 Tc-99                   | release fraction *dose factor*exp(-lambda t)   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 1.07E-06 all nuclides            | sum of nuclides  |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 85.53473 usage                   | 1100*(usage/dilution)/flow   |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |
| 9.14E-05 mRem                    | see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms. |                   |   |  |  | U-234             | U-238             | U-238             | U-238                                      | U-238             | U-234             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238             | U-238   | U-238             |









## Attachment 9 2019 Isotopic Fractions

Based on the plant nominal enrichment for 2019

| <b>Nuclide</b> | <b>Average<br/>wt%</b> | <b>Specific Activity<br/>Ci/g</b> | <b>Weighted<br/>Activity</b> | <b>%<br/>Activity</b> |
|----------------|------------------------|-----------------------------------|------------------------------|-----------------------|
| <b>U-234</b>   | 0.04                   | 6.220E-03                         | 2.388E-06                    | 85.03                 |
| <b>U-235</b>   | 4.42                   | 2.160E-06                         | 9.549E-08                    | 3.40                  |
| <b>U-236</b>   | 0.01                   | 6.470E-05                         | 4.076E-09                    | 0.15                  |
| <b>U-238</b>   | 95.56                  | 3.360E-07                         | 3.211E-07                    | 11.43                 |
| <b>Total</b>   | 100.0                  |                                   | 2.809E-06                    | 100.00                |

Attachment 10 - Comply Results

COMPLY: V1.6.

2/10/2020 4:40

40 CFR Part 61  
National Emission Standards  
for Hazardous Air Pollutants

REPORT ON COMPLIANCE WITH  
THE CLEAN AIR ACT LIMITS FOR RADIONUCLIDE EMISSIONS  
FROM THE COMPLY CODE - V1.6.

Prepared by:

Westinghouse Electric Company  
Columbia Fuel Fabrication Facility  
5801 Bluff Rd. Hopkins, SC 29061

David Wagoner  
803.647.1919

Prepared for:

U.S. Environmental Protection Agency  
Office of Radiation and Indoor Air  
Washington, DC 20460

2019 Annual Dose to the Public due to Gaseous Effluent

-----  
SCREENING LEVEL 2  
-----

DATA ENTERED:

-----

RELEASE RATES FOR STACK 1.

| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 6.390E-14                       |
| U-235   | Y | 2.560E-15                       |
| U-238   | Y | 8.590E-15                       |

RELEASE RATES FOR STACK 2.

| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 4.680E-13                       |
| U-235   | Y | 1.870E-14                       |
| U-238   | Y | 6.280E-14                       |

RELEASE RATES FOR STACK 3.

| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 3.010E-12                       |
| U-235   | Y | 1.200E-13                       |
| U-238   | Y | 4.050E-13                       |

RELEASE RATES FOR STACK 4.

| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 3.200E-12                       |
| U-235   | Y | 1.280E-13                       |
| U-238   | Y | 4.300E-13                       |

RELEASE RATES FOR STACK 5.

| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 1.100E-12                       |
| U-235   | Y | 4.410E-14                       |
| U-238   | Y | 1.480E-13                       |

RELEASE RATES FOR STACK 6.

| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 2.020E-12                       |
| U-235   | Y | 8.080E-14                       |
| U-238   | Y | 2.720E-13                       |

RELEASE RATES FOR STACK 7.



| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 8.700E-13                       |
| U-235   | Y | 3.480E-14                       |
| U-238   | Y | 1.170E-13                       |

RELEASE RATES FOR STACK 8.

| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 1.300E-12                       |
| U-235   | Y | 5.210E-14                       |
| U-238   | Y | 1.750E-13                       |

SITE DATA FOR STACK 1.

Release height 10 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 2.

Release height 11 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 3.

Release height 12 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 4.

Release height 13 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 5.

Release height 15 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 6.

Release height 16 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 7.

Release height 17 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 8.

Release height 18 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

Default mean wind speed used (2.0 m/sec).

NOTES:

-----

Input parameters outside the "normal" range:

Building (width) is unusually WIDE.  
Receptor is unusually FAR.

RESULTS:

-----

Effective dose equivalent:           0.2 mrem/yr.

\*\*\* Comply at level 2.

This facility is in COMPLIANCE.

It may or may not be EXEMPT from reporting to the EPA.

You may contact your regional EPA office for more information.

\*\*\*\*\* END OF COMPLIANCE REPORT \*\*\*\*\*

COMPLY: V1.6.

2/10/2020 2:04

40 CFR Part 61  
National Emission Standards  
for Hazardous Air Pollutants

REPORT ON COMPLIANCE WITH  
THE CLEAN AIR ACT LIMITS FOR RADIONUCLIDE EMISSIONS  
FROM THE COMPLY CODE - V1.6.

Prepared by:

Westinghouse Electric Company  
Columbia Fuel Fabrication Facility  
5801 Bluff Rd. Hopkins, SC 29061

David Wagoner  
803.647.1919

Prepared for:

U.S. Environmental Protection Agency  
Office of Radiation and Indoor Air  
Washington, DC 20460

Hot Oil Room

-----  
SCREENING LEVEL 2  
-----

DATA ENTERED:  
-----

| Nuclide |   | Release Rate<br>(curies/SECOND) |
|---------|---|---------------------------------|
| U-234   | Y | 2.300E-12                       |
| U-235   | Y | 9.210E-14                       |
| U-238   | Y | 3.100E-13                       |

Release height 12 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

Default mean wind speed used (2.0 m/sec).

NOTES:

Input parameters outside the "normal" range:

Building (width) is unusually WIDE.  
Receptor is unusually FAR.

RESULTS:

Effective dose equivalent: 4.6E-02 mrem/yr.

\*\*\* Comply at level 2.

This facility is in COMPLIANCE.

It may or may not be EXEMPT from reporting to the EPA.

You may contact your regional EPA office for more information.

\*\*\*\*\* END OF COMPLIANCE REPORT \*\*\*\*\*